DATASHEET - M22-WRK3



Changeover switch, RMQ-Titan, With thumb-grip, maintained, 3 positions, Bezel: titanium

Powering Business Worldwide

6

M22-WRK3 Part no. 216872 Catalog No. **Alternate Catalog** M22-WRK3Q

No.

EL-Nummer 4355319

(Norway)

Delivery program


| Delivery program | |
|----------------------------|---|
| Product range | RMQ-Titan |
| Basic function | Selector switch actuators |
| Single unit/Complete unit | Single unit |
| Design | With thumb-grip |
| | maintained |
| Function: | |
| | 60° # 60° |
| | 3 positions |
| Degree of Protection | IP66 |
| Front ring | Bezel: titanium |
| Connection to SmartWire-DT | yes with SWD-RMQ connections |
| Front dimensions | 29,7 |
| Instructions | Stay-put/spring-return function, can be changed with coding parts M22-XC-Y with plunger bridge for the middle contact |

Technical data

| General | | | |
|------------------------------------|--------------|-------------------|--|
| Standards | | | IEC/EN 60947 VDE 0660 |
| Lifespan, mechanical | Operations | x 10 ⁶ | > 0.1 |
| Operating frequency | Operations/h | | ≦ 2000 |
| Operating torque (screw terminals) | | Nm | ≦ 0.3 |
| Climatic proofing | | | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| Degree of Protection | | | IP66 |
| Ambient temperature | | | |
| Open | | °C | -25 - +70 |
| Storage | | °C | - 40 - + 80 |
| Mounting position | | | As required |
| Mechanical shock resistance | | g | 30 Shock duration 11 ms Sinusoidal according to IEC 60068-2-27 |
| shipping classification | | | DNV GL LR |
| | | | Lloyd's Register |







Indoor and protected outdoor installation

| Design verification as pe | r IEC/EN 61439 |
|---------------------------|----------------|
|---------------------------|----------------|

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation | In | Α | 0 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 0 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 70 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $ \frac{1}{2} \left(\frac{1}{2} \right) = \frac{1}{2} \left(\frac{1}{2} \right) \left($ | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Please enquire |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | Not applicable. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$ |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss10.0.1-27-37-12-13 [AKF031014])


| Type of control element Suitable for illumination Colour control element Colour indicator light cap Construction type lens Hole diameter Width opening Midth opening Midth opening Switching function latching Spring-return With front ring Material front ring Colour | [AKF031014]) | | | |
|--|---------------------------------------|---|----|---------|
| Suitable for illumination Colour control element Colour indicator light cap Construction type lens Hole diameter Width opening Height opening Switching function latching Spring-return With front ring Material front ring Colour f | Number of switch positions | | | 3 |
| Colour control element Colour indicator light cap Construction type lens Construction type | Type of control element | | | Toggle |
| Colour indicator light cap Construction type lens Hole diameter Midth opening Height opening Midth opening | Suitable for illumination | | | No |
| Construction type lens Hole diameter mm 22.5 Width opening mm 0 Height opening mm 0 Switching function latching Spring-return With front ring Material front ring Colour front ring Colour front ring Colour front ring Round | Colour control element | | | Black |
| Hole diameter mm 22.5 Width opening mm 0 Height opening mm 0 Switching function latching Yes Spring-return No With front ring Yes Material front ring Plastic Colour front ring Other | Colour indicator light cap | | | Other |
| Width openingmm0Height openingmm0Switching function latchingYesSpring-returnNoWith front ringYesMaterial front ringPlasticColour front ringOther | Construction type lens | | | Round |
| Height opening mm 0 Switching function latching Yes Spring-return No With front ring Yes Material front ring Plastic Colour front ring Other | Hole diameter | r | mm | 22.5 |
| Switching function latching Spring-return No With front ring Material front ring Plastic Colour front ring Other | Width opening | r | mm | 0 |
| Spring-return No With front ring Yes Material front ring Plastic Colour front ring Other | Height opening | r | mm | 0 |
| With front ring Waterial front ring Plastic Colour front ring Other | Switching function latching | | | Yes |
| Material front ring Plastic Colour front ring Other | Spring-return | | | No |
| Colour front ring Other | With front ring | | | Yes |
| · | Material front ring | | | Plastic |
| Degree of protection (IP), front side | Colour front ring | | | Other |
| | Degree of protection (IP), front side | | | IP66 |

Approvals

| Product Standards | IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking |
|-----------------------------|--|
| UL File No. | E29184 |
| UL Category Control No. | NKCR |
| CSA File No. | 012528 |
| CSA Class No. | 3211-03 |
| North America Certification | UL listed, CSA certified |
| Degree of Protection | UL/CSA Type 3R, 4X, 12, 13 |

Dimensions





Assets (links)

Declaration of CE Conformity 00003256

Additional product information (links)

IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan System

ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716002Z2018_10.pdf